SARRY ISETT & ASSOCIATES, INC.

Consulting Engineers & Surveyors

www.barryisett.com

100 West Broad Street, Suite 200 P.O. Box 2562 Hazleton, PA 18201-1064

570-455-2999 (FAX: 570 – 454-9979)

Pennsylvania Uniform Construction Code DECK BUILDING PERMIT REQUIREMENTS

A Building Permit is required for a deck where the floor surface is greater than 30 inches above grade at any point.

1. General Construction

- a. All lumber must be pressure treated or naturally durable, such as redwood or cedar.
- b. All hardware must be non-corrosive.
- c. The footings must be a minimum of 36 inches below grade.
- d. The guardrail vertical balusters may have a maximum opening such that a 4" diameter sphere cannot pass through.
- e. The guard rail height may be a minimum of 36-inches and a maximum of 42-inches.

2. Application Requirements

- a. Obtain Township Zoning Approval
- b. Complete a Building Permit Application
- c. Provide four (4) copies of a construction documents, including a site plan.
- d. The construction documents shall include the following:
 - i. Size and spacing of joists
 - ii. Size and spacing of posts
 - iii. Size of beam
 - iv. Size and method to attachment of ledger (the ledger shall be attached to the building using lag or through-bolts only)
 - v. Height of deck above grade

3. Required Inspections

- a. Footing (performed when footings are excavated, prior to pouring concrete)
- Framing (performed prior to installing decking boards this inspection may be omitted at the discretion of the Building Code Official if the framing can be observed from below once the decking boards are installed).
- c. Final (performed when the deck, guardrails, stairs and all associated work is complete).

MAXIMUM ALLOWABLE LUMBER SPANS

Deck Joists

	Deck Joist Spacing			
Joist Size	12" o.c.	16" o.c.	19.2" o.c.	24" o.c.
2" x 6"	10'-0"	9'-1"	8'-7"	7'-11"
2" X 8"	13'-2"	12'-0"	11'-3"	10'-2"
2" x 10"	16'-10"	15'-2"	13'-10"	12'-5"
2" x 12"	20'-4"	17'-7"	16'-1"	14'-4"