

Water Quality Data Table

The table below lists all the drinking water contaminants we detected that are applicable for the calendar year of this report. The present contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of this report. The EPA or the State regulates us to monitor for certain contaminants less than once per year unless because the concentration of these contaminants do not change.

<u>Contaminants</u>	<u>MCLG</u> or <u>MRDLG</u>	<u>MCL</u> TT or <u>MRLD</u>	<u>Your</u> <u>Water</u>	<u>Range</u> <u>Low</u> <u>High</u>	<u>SAMPLE</u> <u>Date</u>	<u>Violation</u>	<u>Typical Source</u>
---------------------	-----------------------------------	------------------------------------	-----------------------------	--	------------------------------	------------------	-----------------------

Inorganic Contaminants

Barium (ppm)	2	2	<0.400		12/30/21	NO	Discharge of drilling wastes: Discharge from metal refineries; Erosion of natural deposit
--------------	---	---	--------	--	----------	----	--

Nitrate [measured as Nitrogen] (ppm)			1.20		05/11/24	NO	Runoff from fertilizer use; leaching from septic tanks, sewage; Erosion of natural deposits
--------------------------------------	--	--	------	--	----------	----	---

Radioactive Contaminants

Alpha emitters (pCi/L)	0	15	1.96	1.40	1.96	10/23/15	NO	Erosion of natural deposits
------------------------	---	----	------	------	------	----------	----	-----------------------------

Radium (combined 226/228) (pCi/L)	0	5	226 228	0.000 + -0.238	0.317 0.348	1/25/22 1/20/22	NO	Erosion of natural deposits
-----------------------------------	---	---	------------	-------------------	----------------	--------------------	----	-----------------------------

Volatile Organic Contaminants

TTHMs [Total Trihalomethanes] (ppb)	NA	.080	0.102			8/15/20	NO	By-products of drinking water disinfection
-------------------------------------	----	------	-------	--	--	---------	----	--

<u>Contaminant</u>	<u>MCLG</u>	<u>AL</u>	<u>Your</u> <u>Water</u>	<u>Sample</u> <u>Date</u>	<u># Samples</u> <u>Exceeding AL</u>	<u>Exceeds AL</u>	<u>Typical Source</u>
--------------------	-------------	-----------	-----------------------------	------------------------------	---	-------------------	-----------------------

Inorganic Contaminants

Lead – action level at consumer taps (ppb)	0	.015	<0.00100	2021	0	NO	Corrosion of household plumbing systems; Erosion of natural deposits
--	---	------	----------	------	---	----	--

Copper- action level at consumer taps (ppm)	1.3	1.3		2021	2	NO	Corrosion of household plumbing systems; Erosion of natural deposits
---	-----	-----	--	------	---	----	--

0.131 – 0.886

<u>Contaminants</u>	<u>MCLG</u> or <u>MRDLG</u>	<u>MCL</u> TT or <u>MRLD</u>	<u>Your</u> <u>Water</u>	<u>Range</u> <u>Low</u> <u>High</u>	<u>SAMPLE</u> <u>Date</u>	<u>Violation</u>	<u>Typical Source</u>
PFOA	8	14	>1.75		2/09/24	NO	Man-made chemicals found in every day products such as soap, makeup, sunscreen, cookware, carpets, clothing, etc.
PFOS	14	18	4.23		2/09/24	NO	
PFOA	8	14	>1.69		5/14/24	NO	
PFOS	14	18	3.45		5/14/24	NO	